



America

CERTIFICATE

No. U8 17 11 97828 002

Holder of Certificate: Rico-Werk
Eiserlo & Emmrich GmbH

Tempelsweg 12-14
47918 Tönisvorst
GERMANY

Production Facility(ies):

97828

Certification Mark:



Product:

C US
Controller unit
(Industrial Control Panel)

Model(s):

=ESP+ ESP Prometos

Parameters:

Rated power range:	5kVA to max. 420kVA 3-Phase 5kVA to max. 360kVA 2-Phase
Rated frequency:	60Hz
Class of equipment:	Class I
IP Protection Class:	IP 54
Enclosure Type rating:	According to UL 50 Type 1 (NEMA 1)

Rated voltage :	
2 Phase with	480Y/277VAC 600Y/347VAC

Rated voltage :	
3 Phase with	480Y/277VAC 600Y/347VAC

Tested according to:

UL 508A:2013/R:2017-07
CAN/CSA-C22.2 No. 14:2013-03

The product was voluntarily tested according to the relevant safety requirements noted above. It can be marked with the certification mark above. The mark must not be altered in any way. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC 17067. Certification is based on the TÜV SÜD "Testing and Certification Regulations". TÜV SÜD America Inc. is an OSHA recognized NRTL and a Standards Council of Canada accredited certification body.

Test report no.: 028-713101835-000

Date, 2017-11-03

Page 1 of 1





CERTIFICATE

No. U8 17 03 97828 001

Holder of Certificate: Rico-Werk
Eiserlo & Emmrich GmbH
 Tempelsweg 12-14
 47918 Tönisvorst
 GERMANY

Production Facility(ies): 97828

Certification Mark:



Product: C US
Controller unit (Industrial Control Panel)

Model(s): =ESP+ESP

Parameters:

Rated power range:	3,5kVA to max. 100kVA
Rated frequency:	60Hz
Class of equipment:	Class I
IP Protection Class:	IP 54
Enclosure Type rating:	According to UL 50 Type 12 (NEMA 12)

Rated voltage :	
2 Phase with	480Y/277VAC 600Y/347VAC

Rated voltage :	
3 Phase with	480Y/277VAC 600Y/347VAC

Unit types considered:	835
------------------------	-----

Tested according to: UL 508A:2013/R:2014-01
 CAN/CSA-C22.2 No. 14:2013-03

The product was voluntarily tested according to the relevant safety requirements noted above. It can be marked with the certification mark above. The mark must not be altered in any way. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC 17067. Certification is based on the TÜV SÜD "Testing and Certification Regulations". TÜV SÜD America Inc. is an OSHA recognized NRTL and a Standards Council of Canada accredited certification body.

Test report no.: 028-713093173-000

Date, 2017-03-10

Page 1 of 1





America

CERTIFICATE

No. U8 17 11 97828 003

Holder of Certificate: Rico-Werk
Eiserlo & Emmrich GmbH

Tempelsweg 12-14
47918 Tönisvorst
GERMANY

Production Facility(ies):

97828

Certification Mark:



C US

Product:

**Controller unit
(Industrial Control Panel)**

Model(s):

=ESP+ ESP Prometos gamma

Parameters:

Rated power range: 10kVA to max. 360kVA 2-Phase
10kVA to max. 420kVA 3-Phase
Rated frequency: 60Hz
Class of equipment: Class I
IP Protection Class: IP 54
Enclosure Type rating: According to UL 50 Type 1
(NEMA 1)

Rated voltage :
2 Phase with 480Y/277VAC
600Y/347VAC

Rated voltage :
3 Phase with 480Y/277VAC
600Y/347VAC

Tested according to:

UL 508A:2013/R:2017-07
CAN/CSA-C22.2 No. 14:2013-03

The product was voluntarily tested according to the relevant safety requirements noted above. It can be marked with the certification mark above. The mark must not be altered in any way. This product certification system operated by TÜV SÜD America Inc. most closely resembles system 3 as defined in ISO/IEC 17067. Certification is based on the TÜV SÜD "Testing and Certification Regulations". TÜV SÜD America Inc. is an OSHA recognized NRTL and a Standards Council of Canada accredited certification body.

Test report no.: 028-713101824-000

Date, 2017-11-09

Page 1 of 1

